

NORTHERN LIGHTS, INC.

The power of local service

Three Phase Service Power Requirements for Prospective Members

****Please fill out all the information on this page****

Name: _____ **Phone#:** _____

Business Name: _____ **Phone#:** _____

Mailing Address: _____
PO Box/Street City State Zip

Service Voltage Required: Please check which voltage applies or fill in the additional information

Our standard voltages are: Grounded Wye 120/208 or 277/480

****Please Note****

Service voltages other than these may be supplied on a case by case basis by special agreement only

120/208: _____ **277/480:** _____ **Other:** _____ **Specify:** _____

LOAD

_____ **KW Initial**

_____ **KW Projected or**

_____ **HP Initial**

_____ **HP Projected or**

_____ **Running Current Initial**

_____ **Running Current Projected**

The member will be required to provide a disconnect switch accessible to and acceptable to NLI, upon which NLI will terminate the conductors from the transformer. This termination point will be acknowledged by both parties as the point where ownership changes.

The member will be required to provide protection for "single phase" conditions. NLI cannot guarantee that one or two phases of a three phase service will not lose power from the source. The member must provide appropriate protection for the member's own equipment for this condition.

I have read the above information and understand that the information given will be used to size the transformers for my service.



Signature of Applicant(s): _____ **Date:** _____